

## What is the difference between SMA and 3.5 mm RF connectors?

September 14, 2021

SMA and 3.5 mm RF connectors are very similar and should be mechanically compatible, but do have some electrical differences that may be important for your application.

For best performance, use SMAs with SMAs and 3.5 mm connectors with 3.5 mm connectors. If you question the connection integrity, you can use connector gages to verify the proper pin and thread locations.

Proper cleaning of the mating surfaces with a lint-free swab and isopropyl alcohol is recommended as well as using a calibrated torque wrench.

For proper torque values of SIGLENT calibration kits, see the [Mechanical Calibration Kit Datasheet](#)

SMA connectors, like those shown below, have a plastic or foam insulator around the center conductor:



3.5 mm connectors have an air insulator:





### **North American Headquarters**

SIGLENT Technologies NA  
6557 Cochran Rd Solon, Ohio 44139  
Tel: 440-398-5800  
Toll Free: 877-515-5551  
Fax: 440-399-1211  
[info@siglent.com](mailto:info@siglent.com)  
[www.siglentamerica.com/](http://www.siglentamerica.com/)

### **European Sales Offices**

SIGLENT TECHNOLOGIES GERMANY GmbH  
Staetzlinger Str. 70  
86165 Augsburg, Germany  
Tel: +49(0)-821-666 0 111 0  
Fax: +49(0)-821-666 0 111 22  
[info-eu@siglent.com](mailto:info-eu@siglent.com)  
[www.siglenteu.com](http://www.siglenteu.com)

### **Asian Headquarters**

SIGLENT TECHNOLOGIES CO., LTD.  
Blog No.4 & No.5, Antongda Industrial Zone,  
3rd Liuxian Road, Bao'an District,  
Shenzhen, 518101, China.  
Tel: + 86 755 3661 5186  
Fax: + 86 755 3359 1582  
[sales@siglent.com](mailto:sales@siglent.com)  
[www.siglent.com/ens](http://www.siglent.com/ens)